

CHAPTER 93

WATER MAINS AND EXTENSIONS

93.01 Purpose

93.02 Requirements

93.01 PURPOSE. The purpose of this chapter is to establish rules and regulations governing the new mains and extensions within the City.

93.02 REQUIREMENTS. All new water mains, either replacing existing lines or extending into new service areas, must meet the following requirements:

1. Mains must be at least 6 inches in diameter or larger as determined by Water Works, taking into account the potential for future use and fire protection by the Fire Underwriters. The minimum six-inch pipe size is applicable in all cases except on courts or cul-de-sacs or such cases where individual conditions will control size, but in no case less than four inches.
2. Mains must be of SDR-21 PVC or DR 18 C900 PVC, laid with tracer wire.
3. Mains must be laid to provide a minimum of five feet of cover.
4. All main extensions or replacements must extend at least 10 feet along the frontage, past the property line of the last property to be served by water.
5. The developer or subdivider is responsible for installing water mains and extensions according to City specifications while contracting directly for such installations, and is responsible for paying the costs thereof directly to the contractor.
6. The developer is only responsible for a hook-up fee of \$125.00 plus permit fee of \$25.00, at the time a dwelling is put on a property.